



## City of Placerville

---

### Engineering Department

3101 Center Street, 3<sup>rd</sup> Floor

Placerville, CA 95667

(530) 642-5250 / (530) 642-5568 fax

### **ADDENDUM NUMBER 2**

**Dated: November 5, 2020**

**to the  
Notice to Bidders, Special Provisions, Proposal and Contract Documents  
for Construction of**

**WESTERN PLACERVILLE INTERCHANGES PROJECT PHASE 2.2  
CIP # 41918**

**Bids Due: Thursday November 12, 2020; 2:00 p.m.  
Via Quest CDN**

This Addendum is issued to the Western Placerville Interchanges Project Phase 2.2. Submit proposals for this work with the understanding and full consideration of this Addendum. The revisions declared in this Addendum are essential parts of the Contract.

Bidders are also directed to sign this Addendum as acknowledged, and attach the complete, signed Addendum to the Proposal.

#### **The following responses to questions asked to date:**

**Question No. 1:** Does the SWPPP need to be prepared in Caltrans format and are Caltrans forms required to be utilized for the monitoring/inspections?

**Answer:** There is no requirement to use Caltrans-specific forms. Forms used must be compliant with the Construction General Permit. Inspections must be performed consistent with a risk level 2 project.

This addendum has been prepared under the direction of the following registered Civil Engineer:

11/5/2020

---

Rebecca Neves, P.E.

Date

Addendum No. 2; Page 2 of 2  
Western Placerville Interchanges Project Phase 2.2  
CIP # 41918  
November 5, 2020

### Acknowledgment:

I have reviewed the materials included in Addendum 2 to the Western Placerville Interchanges Project Phase 2.2 and understand the information provided is included as part of the Special Provisions, Proposal and Contract.

By:

Bidder's Signature

Date \_\_\_\_\_

Bidder's Name (printed)

Name of Company