



City of Placerville

Engineering Department

3101 Center Street, Placerville, CA 95667
(530) 642-5250

ADDENDUM NUMBER 1

Dated: October 10, 2023

to the

**Notice to Bidders, Contract, Proposal, Special Provisions and Plans for Construction of
BROADWAY SIDEWALKS PROJECT CIP #41606
City of Placerville**

**Bids Due: Tuesday, October 17, 2023; 2:00 p.m.
City Hall, 3rd Floor, 3101 Center Street Placerville, California**

This addendum is issued to the Broadway Sidewalks Project. Submit proposals for this work with the understanding and full consideration of this Addendum. The revisions declared in this Addendum are essential parts of the Contract.

Bidders are also directed to sign this Addendum as acknowledged, and attach the complete, signed Addendum to the Proposal.

The following changes are made to the Notice to Bidders, Contract, Proposal, Special Provisions and Project Plans Project Plans:

Notice to Bidders

Replace the paragraph in the Completion of Work section in the Notice to Bidders with the following:

COMPLETION OF WORK: Paving operations are anticipated to occur at night from the hours of 10 pm to 8 am, Sunday through Thursday. Concrete and utility work is anticipated to occur during normal working hours from 7 am to 5 pm, Monday through Friday. No work shall be performed by the Contractor on Friday nights, Saturday, or City designated holidays.

Contract

On page C-19 of the Contract, replace the second and third paragraphs with the following:

This work shall be diligently prosecuted to completion before the expiration of 90 WORKING DAYS beginning on the fifteenth calendar day after the date shown on the Notice to Proceed.

The Contractor shall pay to the City/County the sum of \$4,800.00 per day, for each and every calendar days' delay in finishing the work in excess of the number of working days prescribed above.

Proposal

Replace Contractor's Bid and Bid Price Schedule with revised Contractor's Bid and Bid Price Schedule.

Questions and Answers

The City received the following questions:

Question 1: There are no bid items for permanent pavement delineations. It seems all pavement delineations will be done on Broadway Maintenance contract. If so, can the striping plans be removed from the Broadway Sidewalks project?

City's response to Question 1: Depending on the sequence of work, temporary pavement markings and temporary traffic stripe shown in the Broadway Sidewalks plans may not be necessary. City encourages the Contractor to coordinate with Contractor for the Broadway Maintenance project to minimize the need for temporary pavement markings and temporary traffic stripes.


Question 2: What items are included in the *Connect to Existing Water System* bid item?

City's response to Question 2: Refer to page SP-44 of the Special Provisions for details on what is included in the *Connect to Existing Water System* bid item.

Project Plans

The following sheets of the original Project Plans have been modified as follows:

- Sheet C04: Revised pipe zone bedding materials for both water and storm drain. Pipe zone backfill shall be ¾ inch Class II AB.
- Sheet C09: Modified Construction Note 6. The City has already replaced the damaged fire hydrant at Station 26+53, in front of 1270 Broadway. This hydrant should be reconnected to the main as indicated in the image and revised Special Provisions (below):




CONSTRUCTION NOTES:

- ① 26+08.93 (16.09' R)
REPLACE WATER SERVICE LINE
- ② 26+20.03 (15.98' R)
REPLACE WATER SERVICE LINE
- ③ 26+27.40 (15.73' R)
REPLACE WATER SERVICE LINE
- ④ 26+29.94 (15.64' R)
REPLACE WATER SERVICE LINE
- ⑤ 26+36.63 (15.52' R)
REPLACE WATER SERVICE LINE
- ⑥ 26+53 (24.00' R)
INSTALL FIRE HYDRANT VALVE.
CONTRACTOR TO EXPOSE AND REMOVE
EXISTING CAP ON EXISTING FIRE HYDRANT LEAD
AND INSTALL FIRE HYDRANT VALVE.

GENERAL NOTES:

1. THRUST BLOCKS AND RESTRAINED JOINTS NOT SHOWN FOR CLARITY.
2. FOR BENDS LESS THAN 45 DEGREES, RESTRAINED PIPE JOINTS SHALL BE INSTALLED PER MANUFACTURER'S RECOMMENDATIONS AND PROJECT SPECIAL PROVISIONS.
3. RESTRAINED JOINT LENGTH SHALL BE PER MANUFACTURER'S RECOMMENDATIONS.
4. THRUST BLOCKS SHALL BE INSTALLED AT ALL TEES, BENDS GREATER THAN 45 DEGREES, DEAD ENDS, AND BLIND FLANGES PER THE REQUIREMENTS IN THE PROJECT SPECIAL PROVISIONS, EID WATER DESIGN STANDARDS, EID TECHNICAL SPECIFICATIONS, AND EID STANDARD DRAWING W11 & W11A.
5. QUANTITIES SHOWN REPRESENT IMPROVEMENTS DISPLAYED ON THIS SHEET ONLY.



Special Provisions

Modifications to the Special Provisions are as follows:

- Add to Section 19 EARTHWORK:

Add to section 19-1.03:

It is anticipated that all excavating efforts will be achievable by use of a medium sized excavator, such as a CAT 325 excavator with rock bucket, or other industry approved piece of similar equipment.

- Add to Section 77-4.02B(6)(c) MATERIALS:
Insertion valve shall be either Hydra Stop Instavalue 250, Mueller Permaseal Insertion Valve, Romac Industries Inserta Valve, or approved equal. Insertion valve to be installed per manufacturer's specifications.
- Replace the fourth (4th) paragraph in section 77-4.04 PAYMENT with:
The 10" Gate Valve and Insertion Valve bid items shall be paid for on a per unit basis. Measurement shall be based on the actual number of Gate Valves and Insertion Valves installed. The contract unit price paid for each 10" Gate Valve and Insertion Valve shall include full compensation for all labor, materials, tools, equipment and incidentals, and for doing all the work involved, complete and in place, as specified per Section 3.6 and EID Standard Drawing W12 of the El Dorado Irrigation District Design Standards and as directed by the City Engineer and Department of Public Works, manufacturer's specifications and no additional compensation will be allowed.
- Replace the paragraphs in Section 77-5.02 CONSTRUCTION with:
Contractor is to install a fire hydrant valve at the location indicated in the project plans, in front of 1270 Broadway. Contractor is to expose the existing hydrant lateral and locate the existing cap in the lateral, remove cap, and install new hydrant valve.

Materials which are lost for any reason, and components which are damaged beyond repair as a result of the Contractor's operations shall be either replaced by the Contractor, at his expense. Replacement for lost or damaged components shall be of the same kind and of the same or better quality and condition as the lost or damaged materials were prior to their removal.
- Replace the paragraph in Section 77-5.03 PAYMENT with:
The Install Fire Hydrant Valve bid item shall be paid for by lump sum. The contract unit price paid for Install Fire Hydrant Valve shall include full compensation for all labor, materials, tools, equipment and incidentals, and for doing all the work involved, complete and in place, as specified per EID Standard Drawing W17 of the El Dorado Irrigation District Design Standards and as directed by the City Engineer and Department of Public Works, Project Plans and Special Provisions and no additional compensation will be allowed. Work involved includes and is not limited to: furnishing all labor, materials, tools, equipment, and incidentals, and for doing all the work involved in installing the hydrant valve, including all sawcutting; excavation; backfill; locating, cutting, removing, and disposing existing cap on hydrant lateral; new hydrant lateral piping as needed; new hydrant valve; reconnecting relocated hydrant to existing fire service line, disposal of excess materials, and any necessary surface restoration.

- Add to section 77-1.02B Pipe Zone
Material for the pipe zones for water service lines shall be consistent with Section 19-3.02F(2) of the Caltrans standards Specifications:

Sand bedding must consist of sand:


1. Free of clay or organic material
2. Suitable for the purpose intended
3. Complying with the gradation requirements shown in the following table:

Sieve size	Percentage passing
No. 4	90–100
No. 200	0–5

Attachments:

- Revised Contractor's Bid and Bid Price Schedule
- Sign-in sheet from Pre-Bid Conference

This addendum has been prepared under the direction of the following registered Civil Engineer:



10/10/2023

James W. Fisher, PE

Date

Exhibit A
CITY OF PLACERVILLE
CONTRACTOR'S BID AND BID PRICE SCHEDULE
Broadway Sidewalks Project (CIP# 41606)
Federal Project No. HSIPL – 5015 (028)

F/P	Item No.	Caltrans Item Code	Item Description	Unit of Measure	Estimated Quantity	Unit Price (In Figures)		Item Total (In Figures)	
	1	760090	Mobilization/Demobilization	LS	1	\$		\$	
	2	120100	Traffic Control System	LS	1	\$		\$	
	3		Construction Staking	LS	1	\$		\$	
	4	070030	Lead Compliance Plan	LS	1	\$		\$	
	5	130201	Water Pollution Control Plan	LS	1	\$		\$	
	6	130620	Temporary Drainage Inlet Protection	EA	6	\$		\$	
	7	398300	Remove Base & Surfacing	CY	1,060	\$		\$	
	8	398200	Cold Plane	SF	5,900	\$		\$	
	9		Remove Parking Bumper	EA	3	\$		\$	
	10		Remove and Relocate Parking Bumper	EA	45	\$		\$	
F	11		Remove Walls at 1277 and 1283 Broadway	LS	1	\$		\$	
	12	846030	Remove Striping	LF	220	\$		\$	
	13		Relocate Irrigation Box	EA	1	\$		\$	
	14		Adjust Water Utility to Grade	EA	13	\$		\$	
	15		Adjust Sewer Utility to Grade	EA	9	\$		\$	
	16		Adjust Irrigation Utility to Grade	EA	3	\$		\$	
	17		Adjust Electric Utility to Grade	EA	3	\$		\$	
	18		Remove Abandoned Fire Hydrant	EA	1	\$		\$	
	19	250201	Class II AB	CY	427	\$		\$	
	20	390132	Type A HMA	TON	356	\$		\$	
	21	730010	Minor Concrete (Curb) Type A	LF	280	\$		\$	
	22	730010	Minor Concrete (Curb) Type B	LF	400	\$		\$	
	23		Minor Concrete (Wall) Type C	LF	200	\$		\$	
	24	731504	Minor Concrete (Curb & Gutter)	LF	1,730	\$		\$	
	25	731521	Minor Concrete (Sidewalk)	SF	5,200	\$		\$	
	26	731516	Minor Concrete (Driveway)	SF	2,900	\$		\$	
F	27		Minor Concrete (Stairs)	CY	3	\$		\$	
F	28		Retaining Wall	CY	50	\$		\$	
	29		Retaining Wall (Wood)	SFF	40	\$		\$	
	30	820610	Relocate Roadside Sign	EA	5	\$		\$	
	31	120149	Temporary Pavement Marking	SF	50	\$		\$	
	32	120159	Temporary Traffic Stripe	LF	800	\$		\$	
	33	840666	Pavement Paint	SF	600	\$		\$	
	34	820840	Install Roadside Sign	EA	4	\$		\$	
	35	780500	Parking Bumper	EA	60	\$		\$	
	36	700617	DI Marker	EA	4	\$		\$	
	37		Under Sidewalk Drain	EA	5	\$		\$	
	38	730070	Detectable Warning Surface	EA	2	\$		\$	

F/P	Item No.	Caltrans Item Code	Item Description	Unit of Measure	Estimated Quantity	Unit Price (In Figures)		Item Total (In Figures)	
	39		Relocate Pedestrian Push Button Sign	EA	1	\$		\$	
	40		12" HDPE	LF	260	\$		\$	
	41		60" SDMH	EA	1	\$		\$	
	42		Type B DI	EA	3	\$		\$	
	43		Remove and Replace Water Service Line	EA	9	\$		\$	
	44		10" PVC C-900	LF	760	\$		\$	
	45		Remove 4" Water Main	LF	270	\$		\$	
	46		Connect to Existing Water System	EA	3	\$		\$	
	47		10" Gate Valve	EA	8	\$		\$	
	48		Remove Concrete Base	CY	240	\$		\$	
	49		Install Fire Hydrant Valve	EA	1	\$		\$	
	50		Insertion Valve	EA	1	\$		\$	

TOTAL BID AMOUNT FOR BROADWAY SIDEWALKS PROJECT:

\$ _____

Total Project Bid Amount for Item No.'s 1 through 50 shall be (spell out):

_____ **Dollars and**

_____ **Cents.**

SIGNATURE OF BIDDER

PRINT NAME OF BIDDER

PRINT TITLE OF BIDDER

(NOTICE: Bidder's failure to execute the questionnaires and statements contained in the Proposal as required by applicable laws and regulations, or the determinations by the City of Placerville based upon those questionnaires and statements, may prohibit award of the subject Contract to the Bidder.)

City of Placerville
Mandatory Pre-Bid Meeting for
Broadway Sidewalks Project CIP# 41606 &
Broadway Maintenance Project CIP# 42003
October 3, 2023 @ 10:00 am



Sign-In Sheet

INITIAL	NAME	ORGANIZATION	EMAIL	PHONE
DM	Daniel Marquez	FBD Vanguard	dmarquez@v-inc.net	925-500-7628
BJ	Ben Jeffrey	Road-Tech	ben@road-tech.com	530-672-0222
BF	Bayley Follett	central valley Eng. + Asphalt	Bayley@cenvalley.com	916-952-3111
KU	Kathy Verhoeven	Martin Gen Engineering	estimating@martingencal.net	916-3558001
MC	Mario Cardoza	OE3	mcardoza@oe3.org	916-886-3548
RL	ROBERT LEWIS	PROBUILDERS	ROBERT@SACPROBUILDERS.COM	916 491 0039
M	Matt Veerkamp	DVGE	math.veerkamp@dongveerkamp.com	530 409-0857
ES	ERICA SALANON	B & M	estimating@bm-builders.com	916 638 8100
JF	JIM FISHER	R.E.Y.	JFISHER@REYENGINEERS.COM	916 366-3040
DC	Doug Corr	Dewberry	dccorr@dewberry.com	916 276-4721
RN	Rebecca Neves	City of Placerville	rneves@cityofplacerville.org	530-642-5250
MM	Melissa McConnell	City	mmcconnell@cityofplacerville.org	530 642 5250
VGM	Veronica Garcia	REY	vzgarcia@reyengineers.com	(916) 366 3040