



2018 Annual Water Quality Report A Consumer Confidence Report



This report contains important information about your drinking water. (Este informe contiene información muy importante sobre su agua potable. Tranúzcalo ó hable con alguien que lo entienda bien.)

The City of Placerville and El Dorado Irrigation District (EID) take pride in the quality of water delivered to their customers. This report summarizes the test results of water samples taken by EID and City staff as required by the U. S. Department of Environmental Protection and the California Department of Public Health.

Things You Should Know About Your Drinking Water ~

- ◆ *Drinking water*, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The term “contaminant” as used in this document refers to any substance in water, other than pure water itself that is regulated and monitored for health and aesthetic reasons. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA’s Safe Drinking Water Hotline (800-426-4791) or by visiting <http://www.epa.gov/safewater/>
- ◆ The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activities (see list at right).
- ◆ Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV / AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA / Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).
- ◆ In order to ensure that tap water is safe to drink, the U. S. Environmental Protection Agency (USEPA) and the California Department of Public Health (CDPH) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. CDPH regulations also establish limits for contaminants in bottled water that must provide the same protection for public health.

Contaminants That May Be Present In Source Water ~

- ◆ **Microbial contaminants**, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- ◆ **Inorganic contaminants**, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharge, oil and gas production, mining or farming.
- ◆ **Pesticides and herbicides**, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- ◆ **Organic chemical contaminants**, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- ◆ **Radioactive contaminants**, that can be naturally-occurring or be the result of oil and gas production and mining activities.

Please be aware that the City is not responsible for plumbing and treatment devices installed on private property. Substandard, illegal, old, improperly installed and/or improperly maintained plumbing or water treatment devices installed by others may adversely affect the water quality coming from the taps inside your home or business.

Abbreviations & Definitions used in this report:

- ◆ **MCL – Maximum Contaminant Level:** The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.
- ◆ **MCLG – Maximum Contaminant Level Goal:** Set by the USEPA, The level of a contaminant in drinking water below which there is no known or expected risk to health. State EPA goals are called PHG (Public Health Goals).
- ◆ **MRDL – Maximum Residual Disinfectant Level:** The level of a disinfectant added for water treatment that may not be exceeded at the consumer’s tap.
- ◆ **MRDLG – Maximum Residual Disinfectant Level Goal:** The level of a disinfectant added for water treatment below which there is no known or expected risk to health. MRDLGs are set by the U.S. Environmental Protection Agency.
- ◆ **ND:** Not detectable at testing limit.
- ◆ **NTU – Nephelometric Turbidity Unit:** A measure of the clarity of the water. Turbidity is a measure of the cloudiness of the water.
- ◆ **TT – Treatment Technique:** A required process intended to reduce the level of a contaminant in drinking water.

For more information about this report or to obtain additional copies, visit the city website at <https://www.cityofplacerville.org/> or call (530) 642-5232.

2018

Source Water Quality - (El Dorado Irrigation District)

Primary Standards - Health Based (units)	Primary	MCL	PHG (MCLG)	Highest Single Measurement	Average	Level	MCL Violation?	Most Recent Sampling Date	Typical Source of Constituent
Turbidity									
Highest single measurement of the Treated Surface Water (NTU)	TT = 1.0		n/a	0.56		n/a	No	2018	Soil runoff
	Primary	MCL	PHG (MCLG)	Range of Detection	Average	Level	MCL Violation?	Most Recent Sampling Date	Typical Source of Constituent
Ciardia lambia (oocyst/L)	TT		0	ND-0.10		0.0	No	2017	Runoff/leaching from natural deposits; seawater influence
Secondary Standards - Aesthetic (units)	Secondary MCL	PHG (MCLG)	Range of Detection	Average	Level	MCL Violation?	Most Recent Sampling Date	Typical Source of Constituent	
Aluminum (mg/L)	200		n/a	ND-97		49.0	No	2017	Erosion of natural deposits; residue from some surface water treatment processes
Chloride (mg/L)	500		n/a	ND-3.7		2.1	No	2018	Runoff/leaching from natural deposits; seawater influence
Corrosivity (A.I.)	Non-corrosive		n/a	9.8-10.0		9.90	No	2018	Natural or industrially-influenced balance of hydrogen, carbon and oxygen in the water; affected by temperature and other factors
Odor-Threshold (units)	3		n/a	2		2	No	2018	Naturally-occurring organic materials
Specific Conductance (µS/cm)	1600		n/a	50-72		59	No	2018	Substances that form ions when in water; seawater influence
Sulfate (mg/L)	500		n/a	ND-1.7		0.6	No	2018	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (mg/L)	1000		n/a	41-50		45	No	2018	Runoff/leaching from natural deposits
Turbidity (NTU)	5		n/a	0.12-0.13		0.13	No	2018	
Other Parameters (units)	Notification Level	PHG (MCLG)	Range of Detection	Average	Level	MCL Violation?	Most Recent Sampling Date	Typical Source of Constituent	
Alkalinity (mg/L)	Unregulated	n/a	16-27		21	n/a	2018	No Know Typical Source of Constituent	
Bicarbonate (mg/L)	Unregulated	n/a	19-33		26	n/a	2018		
Calcium (mg/L)	Unregulated	n/a	3-5		4	n/a	2018		
Chlorate (ug/L)	800	n/a	ND-300		95	n/a	2017		
Hardness as CaCO3 (mg/L)	Unregulated	n/a	11-22		15	n/a	2018		
Hardness as CaCO3 (grains/gal)	Unregulated	n/a	0.64-01.29		0.88	n/a	2018		
Hexavalent Chromium (ug/L)	Unregulated	0.02	ND-0.07		ND	n/a	2013		
Magnesium (mg/L)	Unregulated	n/a	0.7-2.2		1.3	n/a	2018		
pH (pH units)	Unregulated	n/a	7.4-7.8		7.6	n/a	2018		
Sodium (mg/L)	Unregulated	n/a	5.3-6.7		6	n/a	2017		
Strontium (ug/L)	Unregulated	n/a	ND-53		35	2018	2013		
Vanadium (ug/L)	50	n/a	ND-0.63		0.18	n/a	2013		
Disinfection Byproduct Precursors (units)	Action	Level	PHG (MRDLG)	Range of Detection	Lowest RAA Quarterly Average	MCL Violation?	Most Recent Sampling Date		Typical Source of Constituent
Total Organic Carbon [TOC] Filtered water (mg/L)	TT=	Removal	n/a	0.88-1.60		n/a	2018	Various natural and manmade sources	
Total Organic Carbon [TOC] Removal Ratio (Actual/Required)	TT=<	1.0	n/a	n/a		1.00	No	2018	Various natural and manmade sources

City of Placerville Distribution System Water Quality - Main System¹

Microbiological Constituents (units)	Primary MCL	PHG (MCLG)	Value	MCL Violation?	Most Recent Sampling Date	Typical Source of Constituent	
Total Coliform Bacteria > 12 Samples/Month (Present / Absent)	No more than 5% positive monthly sample	(0)	No samples were positive	No	2018	Naturally present in the environment	
Disinfection Byproducts and Disinfectant Residuals (units)	Primary MCL (MRDL)	PHG (MRDLG)	Range of Detection	Highest Running Annual Average (RAA)	MCL Violation?	Most Recent Sampling Date	Typical Source of Constituent
Chlorine [as Cl ₂] (mg/L)	(4.0)	(4)	0.48-0.62	0.54	No	2018	Drinking water disinfectant added for treatment
HAA5 [Total of five Haloacetic Acids] (ug/L)	60	n/a	22-54	45	No	2018	Byproduct of drinking water disinfection
TTHMs [Total of four Trihalomethanes] (ug/L)	80	n/a	29-50	42	No	2018	Byproduct of drinking water disinfection
Inorganic Constituents (units)	Action Level	PHG (MCLG)	Sampe Data	90th % Level	MCL Violation?	Most Recent Sampling Date	Typical Source of Constituent
Copper (mg/L)[at the tap]	1.3	0.3	None of the 20 smaple sites collected exceeded the action level	0.17	No	2018	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Lead (ug/L)[at the tap]	15	2	None of the 20 smaple sites collected exceeded the action level	None Detected	No	2018	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
<p>Historically the City of Placerville was divided into 2 water systems, the Main and Sierra Water Systems. With the completion of the Blairs Bridge project, and a recent permit amendment approved by the California State Water Resources Control Board, they were combined into 1 system, which is now known as "City of Placerville Main Water System"</p>							